



Purchasing Department

209 Water Street
Johnson City, TN 37601
(423) 975-2716

ADDENDUM

TO: All Prospective Vendors

FROM: Valerie Harless
Assistant Director of Purchasing

SUBJECT: Addendum No1 ITQ #2018-46 Waste Sludge Pump

DATE: November 8, 2018

Consider this addendum an integral part of the above referenced Invitation to Quote:
Additional information:

- 1) What is temperature of fluid being pumped **70°F**
- 2) What is solids size **1 inch sphere**
- 3) What is viscosity of fluid being pumped **5% sludge (not really sure). I used Hazen Williams coefficient of C=160 and density of 1.07SG**
- 4) What maximum flow rate do you need (600?)?. What is minimum that you could use(300?)? **600 gpm is max 300 gpm is min**
- 5) What is electrical voltage available **208-230 V available**

All other specifications remain the same. **Vendor to acknowledge receipt of this addendum by initialing and returning the addendum notice with the return bid package or via facsimile if it has already been submitted.** Your unopened response envelope can be returned to you for re-submittal upon request. Any questions regarding addendum submittal please contact this office.

/vh